

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M A P P S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 C.I.T 58

CON'T

0	1	REPORT SOURCE		L	6	0	5	0	-	0	2	9	3	7	0	6	1	9	8	1	8	0	7	2	0	8	1	9
7	8	60	61	POCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On June 19, 1981 at 1445 hours, the Reactor Coolant Leak Detection Air Sampling System (C-19) was declared inoperable. Instrument and Control personnel were immediately dispatched to repair the unit. During the event the drywell sumps were operable. C-19 was repaired and returned to service at approximately 2032 hours on the same day. The unit has operated satisfactorily since that time.

SYSTEM CODE C T 11		USE CODE E 12		CAUSE SUBCODE X 13		COMP. SUBCODE C 15		VALVE SUBCODE A 16	
EVENT YEAR 8 1 22		SEQUENTIAL REPORT NO. 0 3 2 26		OCCURRENCE CODE / 27		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22	
ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER 3 25		COMPONENT MANUFACTURER R 3 6 2 26			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by dirt in the system check valves which caused the valves

1 1 | to stick in the closed position. The check valves were disassembled, cleaned,

1 2 | and reassembled. This is an isolated event.

1 3 |

1 4 |

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	1	0	0	N.A.			A	Operational Event				
ACTIVITY CONTENT						AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
1	6	Z	Z	N.A.			N.A.							
PERSONNEL EXPOSURES			TYPE			DESCRIPTION								
1	7	0	0	0	Z	N.A.								
PERSONNEL INJURIES			DESCRIPTION											
1	8	0	(N.A.										
LOSS OF C			MAGE TO FACILITY											
1	9	Z	N.A.											
PUBLICITY			DESCRIPTION			8107280447 810720 PDR ADOCK 05000293 S PDR								
2	0	N	N.A.			NRC USE ONLY								

NAME OF PREPARER M. T. McLoughlin

PHONE: 617-746-7900