

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5									
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35									
LICENSEE CODE														LICENSE NUMBER										LICENSE TYPE										CAT		58	

CON'T

0	1	L	6	0	5	0	0	0	3	1	7	7	0	6	1	3	8	1	8	0	7	1	3	8	1	9					
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35			
REPORT SOURCE		DOCKET NUMBER										EVENT DATE										REPORT DATE									

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During the past 30 days, pressurizer level has deviated from the program level by more than 5% several times (T.S. 3.4.4). For 30 minutes on June 26, and 15 minutes on June 30, the pressurizer level exceeded the 5% band while paralleling the main generator. For 7 minutes on June 13 the 5% band was exceeded as charging and letdown were isolated to investigate slightly increased RCS leakage. LER 81-40 describes a similar event.

0	9	C	B	11	X	12	Z	13	Z	Z	Z	Z	Z	Z	14	Z	15	Z	16	17	8	1	—	0	5	3	—	0	3	L	—	0
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE										COMP. SUBCODE		VALVE SUBCODE		LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACT. JTR																
Z		Z		Z		Z		0000		N		N		Z		Z999																

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

RCS temp. swings of 10 degrees are not uncommon when paralleling the main generator. These temp. swings can result in deviations greater than 5% from pressurizer program level. Occasionally, isolation of charging and letdown is necessary and may cause deviations from the 5% band due to RCP controlled bleedoff. No corrective action is deemed necessary.

1	5	C	28	0	2	0	29	NA	A	31	Operator Observation	32	
7	8	9	10	11	12	13	14	15	16	17	18	19	
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE							
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION							
PERSONNEL INJURIES		NUMBER		TYPE		DESCRIPTION							
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION									
PUBLICITY		ISSUED		DESCRIPTION									
8107280480		810713		PDR		ADDOCK		05000317		PDR		NRC USE ONLY	
2		0		N		44		NA		S		PHONE	

NAME OF PREPARER

M. A. Junge

PHONE

(301) 269-4747