

DMB 50.55(e)
DN 50-482



KANSAS GAS AND ELECTRIC COMPANY

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

July 15, 1981



Mr. G.L. Madsen, Chief
Reactor Projects Branch
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

KMLNRC 81-099
Re: NRC Docket No. 50-482
Ref: Interim Report dated May 14, 1981 transmitted
by GLKoester Letter (KMLNRC 81-078) to
WCSeidle, NRC
Subj: Interim 50.55(e) Report on Nuclear Coatings in
the Reactor Building

Dear Mr. Madsen:

This letter is to provide an update on the evaluation of the nuclear coatings applied in the Reactor Building of the Wolf Creek Generating Station.

As indicated in the Referenced Report, the Architect/Engineer has completed their evaluation and recommendations of the nuclear coating applied prior to July 25, 1980. They have recommended that if the missing supporting documentation of the areas in question cannot be obtained, then adhesion pull tests should be performed.

The status of the search for the missing documentation and/or a schedule for the adhesion pull tests, if required, will be reported to you on or before October 2, 1981. If you require any additional information, please feel free to contact us.

Yours very truly,

Glenn L Koester

GLK:bb

cc: TVandel, NRC Site Inspector

8107280539 810715
PDR ADOCK 05000482
S PDR

IE27
5
1/0