

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

0 1 N E C P R 1 2 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	2	9	8	7	0	6	0	8	8	1	8	0	6	2	4	8	1	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During routine surveillance testing, the HPCI pump turbine tripped on overspeed

0 3 prior to reaching rated system flow. The HPCI system was declared inoperative. The

0 4 redundant system, ADS, was operable as were the RCIC and LPCI systems. This event

0 5 is not repetitive. There were no adverse effects on the public health and safety.

0 6

0 7

0 8

0 9
7 8

SYSTEM CODE
S F 11
9 10

CAUSE CODE
D 12
11

CAUSE SUBCODE
Z 13
12

COMPONENT CODE
V A L V E X 14
13 18

COMP. SUBCODE
A 15
19

VALVE SUBCODE
H 16
20

17 LER/RO REPORT NUMBER
EVENT YEAR
8 1
21 22

SEQUENTIAL REPORT NO.
0 1 4
24 26

OCCURRENCE CODE
0 3
28 29

REPORT TYPE
L
30

REVISION NO.
0
32

ACTION TAKEN
G 18
33

FUTURE ACTION
Z 19
34

EFFECT ON PLANT
Z 20
35

SHUTDOWN METHOD
Z 21
36

HOURS
0 0 0 0
37 40

ATTACHMENT SUBMITTED
N 23
41

NPRD-4 FORM SUB.
24
42

PRIME COMP. SUPPLIER
N 25
43

COMPONENT MANUFACTURER
T 1 4 7
44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 'This occurrence was caused by an improper valve line-up procedure. The procedure
1 1 stated the HPCI trip unit oil supply valve should be "open". This valve should be
1 2 throttled to maintain ~ 20 psig unit oil supply. Excessive oil pressure caused the
1 3 turbine to trip below operating speed. The valve was throttled. The system tested
1 4 satisfactorily. The procedure has been revised. No further action is planned.

FACILITY STATUS (28) C 0 2 3 (29) NA (30) OTHER STATUS
 ACTIVITY CONTENT RELEASED OF RELEASE (33) Z (34) Z (35) NA
 METHOD OF DISCOVERY (31) B (32) Surveillance Test
 LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
1 7	0 0 0	NA

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	0	0	0
		(40)	NA

8107280619 810624
PDR ADOCK 05000298
S PDR

2	0	N	(44)	NA	68	69	80
---	---	---	------	----	----	----	----

NAME OF PREPARER Richard D. Flannigan

PHONE: 402-825-3811