

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A R A N 0 1 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 L 6 0 5 0 0 0 3 1 3 7 0 6 0 2 8 1 8 0 7 0 2 8 1 9
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2 During Power Operation, the Sodium Hydroxide Tank, T10, level fell below
0 3 the Tech Spec required 33.2 feet during the execution of the Spray Pump,
0 4 P35A, Surveillance Test. Samples were immediately taken to determine
0 5 makeup requirements. Minimum level on T10 was 31.8 feet. There have
0 6 been no similar occurrences. Reportable per T.S. 6.12.3.2.b.
0 7 _____
0 8 _____
7 8 9

0 9 S B 11 D 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16
7 8 9 SYSTEM CODE 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 18 COMP. SUBCODE 19 VALVE SUBCODE 20

17 8 1 0 0 8 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

G 18 Z 19 Z 20 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
1 0 Investigation revealed that the test procedure contained multiple steps
1 1 which assumed familiarity with the system layout and functional
1 2 idiosyncrasies. The procedure has been revised for clarification. This
1 3 Sodium Hydroxide Tank was returned to the required level meeting the
1 4 requirements of T.S. 3.3.6.
7 8 9

1 5 E 28 0 9 9 29 NA 30 A 31 Operator Observation 32
7 8 9 FACILITY STATUS 10 % POWER 11 OTHER STATUS 12 METHOD OF DISCOVERY 13 DISCOVERY DESCRIPTION 14

1 6 Z 33 Z 34 NA 35 NA 36
7 8 9 ACTIVITY CONTENT 10 RELEASED OF RELEASE 11 AMOUNT OF ACTIVITY 12 LOCATION OF RELEASE 13

1 7 0 0 7 37 Z 38 NA 39
7 8 9 PERSONNEL EXPOSURES 10 NUMBER 11 TYPE 12 DESCRIPTION 13

1 8 0 0 0 40 NA 41
7 8 9 PERSONNEL INJURIES 10 NUMBER 11 DESCRIPTION 12

1 9 Z 42 NA 43
7 8 9 LOSS OF OR DAMAGE TO FACILITY 10 TYPE 11 DESCRIPTION 12

2 0 NA 45
7 8 9 PUBLICITY 10 ISSUED 11 DESCRIPTION 12

NAME OF PREPARER Chris N. Shively PHONE: (501) 968-2519
7 8 9 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80