

Mailing Address
Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



July 16, 1981

Docket No. 50-348

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. S. A. Varga

Joseph M. Farley Nuclear Plant - Unit No. 1
Inservice Testing Program

Gentlemen:

In accordance with the requirements set forth in 10CFR50, Section 50.55a(g)(6)(i), Alabama Power Company hereby submits seven copies of Revision 3 of the document entitled "Joseph M. Farley Nuclear Plant - Unit No. 1 Inservice Testing Program". The items revised are indicated on these document replacement pages.

The purpose of this revision is to add a list of ASME Section XI Category E valves as requested by letter dated 2/10/81 from S. A. Varga to F. L. Clayton, Jr. In addition, the following changes are being submitted:

Deletion of leak rate test requirement on
valve Q1E21V077C

Addition of the stroke time measurement
requirement on valves Q1N21V001A, B, and C

Addition of containment isolation valves
Q1P19V004 and Q1P19HV2228 and subsequent
relief request

Clarification of containment purge supply
and exhaust valves Q1P13V281, V282, V283
and V284.


1047
5
1/1

Joseph M. Farley Nuclear Plant - Unit No. 1
Inservice Testing Program
July 16, 1981
Page 2

It is hereby requested that the subject program, as revised, be approved and the ASME Section XI Code Relief requested be granted pursuant to Section 50.55a(g)(6)(i) of 10CFR50.

Should you have any questions, please advise.

Yours truly,

A handwritten signature in dark ink, appearing to read "F. L. Clayton, Jr.", with a stylized flourish at the end.

F. L. Clayton, Jr.

WGW:bs

Enclosures

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge
Mr. J. P. O'Reilly
Mr. E. A. Reeves
Mr. W. H. Bradford