

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3371
File # 10010

July 27, 1981

Mr. Spottswood Burwell

Mr. Spottswood Burwell
U. S. Nuclear Regulatory Commission
Licensing Project Manager
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
PSB SITE VISIT
SEPARATION AT HOT SHUTDOWN PANEL

Dear Mr. Burwell:

During the Power Systems Branch Site Visit at Comanche Peak Steam Electric Station (CPSES), concerns were expressed over the separation between Class IE and Non-Class IE circuits at the transfer switches for the Hot Shutdown Panel. This design is still in progress as part of the Alternate Shutdown Study being performed for CPSES and the drawings viewed during the site visit were preliminary.

It is recognized that adequate separation must be provided between Class IE and Non-Class IE circuits at transfer switches for the Hot Shutdown Panel. Adequate separation will be provided. Presently we are examining isolation cords or interposing relays.

If you have any questions, please call.

Sincerely,

A handwritten signature in dark ink, appearing to read "H. C. Schmidt".

H. C. Schmidt

DRW:tls

cc: ARMS

R. D. Calder
J. T. Merritt
J. C. Kuykendall
R. A. Jones
A. T. Parker
R. E. Ballard
Narinder Trehan

*Boo
5/10*