



OFFICIAL COPY

TO: DIRECTOR, OFFICE OF INSPECTION & ENFORCEMENT, REGION 11

DUKE POWER COMPANY
OCONEE NUCLEAR STATION
NRC NOTIFICATION OF REPORTABLE OCCURRENCE

TIME/DATE OF INCIDENT 1100 6/30/81 TIME/DATE OF DISCOVERY 1100 6/30/81
UNIT(S) 1, 2, 3 UNIT STATUS AT TIME OF INCIDENT Cold SP, 100%, 100%
DESCRIPTION OF INCIDENT: During each performance of
Procedure OP/04/110-7/02, ^{NORMAL POWER} THE BACKUP FUNCTION OF
ALL THREE UNITS ISOLATING AND TRANSFER DIODES
ON THE 125 VDC INVERT AND CONT. SYSTEM
WAS ~~PERFORMED~~ OBSERVED. THIS OCCURRED ON 4/9/81 AND
10/29/80.
HOW INCIDENT WAS DISCOVERED: ROUTINE CHECK

IMMEDIATE CORRECTIVE ACTION: A PROPOSED TECH. SPEC. CHANGE
WILL BE SUBMITTED. THE PROCEDURE WILL NOT
BE PERFORMED AS IS UNTIL APPROVAL OF CHANGE
IS OBTAINED.

REPORTABLE PURSUANT TO TECHNICAL SPECIFICATION 6.6.2, K9(2)
DATE REPORT DUE TO NRC/OIE 7/14/81
TIME/DATE TELECOPIED OR OTHERWISE TRANSMITTED TO NRC/OIE 0915 7/1/81
PREPARED BY Glenn Rogers

PHONE (803) 882-5363
REGIONAL DIRECTOR
DEPUTY DIRECTOR
ASSISTANT TO DIRECTOR
DIRECTOR, RRPI
DIRECTOR, EPOS
DIRECTOR, ENF/INV
DIRECTOR, ETI
PUBLIC AFFAIRS OFFICER

IE29
5/1/8