

Mailing Address
Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building

Alabama Power

the southern electric system

June 24, 1981

Docket No. 50-364

Mr. J. P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303



SUBJECT: J. M. Farley Nuclear Plant Unit 2 Special Report
REFERENCE: Unit 2 Technical Specification 3.7.12

Dear Mr. O'Reilly:

This Special Report is being submitted as required by Unit 2 Tech. Spec. 3.7.12.

At 1300 on 5-18-81, during an inspection by the plant Fire Marshall, a fire barrier penetration in the cable spreading room was declared inoperable due to its not being properly sealed.

Tech. Spec. 3.7.12, in part, requires the above penetration to be functional. Tech. Spec. 3.7.12 action statement requirements were met.

The penetration was sealed, inspected, and returned to service at 1630 on 6-13-81.

Yours very truly,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

FLCJr/JRC:nac

xc: Mr. W. H. Bradford
Mr. W. G. Hairston
File

IEA
5/10