

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	6	4	7	0	6	0	4	8	1	8	0	7	0	7	8	1	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE			
0	9	R	B	A	X	Z	Z	Z	Z	Z	Z	Z	Z				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
LER NO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	8	1	—	0	2	3	—	0	3	L	—	0					
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
X	18	H	Z	Z	Z	0	0	0	0	Y	N	N	Z	Z	9	9	9
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
1	5	E	28	0	4	0	29	NA	A	31	C & HP Notification																																						
ACTIVITY CONTENT										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																													
1	6	Z	33	Z	34	NA	NA																																										

PERSONNEL INJURIES		(41)
NUMBER	DESCRIPTION	
1 2 0 0 0 40	NA	

1 9 Z (42) NA
7 8 9 10
PUBLICITY
ISSUED - DESCRIPTION (45) B107310365 B10707
PDR ADDCK 05000364 NRC USE ONLY

2 0 N 4 NA S PDR

PHONE: (205) 899-5156

7-7-81

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (Continued)

Spec. 3.1.2.6 action statement requirements were met. Health/safety of the public was not affected.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (Continued)

of 7000 ppm when the lines from the Recycle Evaporator to the BAT were flushed with pure water following a "bottoms" transfer. This is done in order to prevent solidification of Boric Acid in the lines. This resulted, however, in the concentration being reduced to less than 7000 ppm (6503 ppm). Again, prior to discovery of the 2A BAT condition, BAT 2B had been in use for Boration which resulted in a volume of less than 11,336 gallons (7980 gallons). Following restoration of the proper concentration and volume, the Boric Acid Storage System was returned to service at 1945 on 6-4-81 and 1920 on 6-16-81. Procedure FNP-2-SOP-2.2, Recycle Evaporator Operation, will be changed to include additional guidance for flushing operations in order to preclude the BAT concentration from deviating from Tech. Spec. requirements. This event will be discussed with licensed personnel in future License Retraining.