

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	A	L	J	M	F	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5			
9		LICENSEE CODE						14	15	LICENSE NUMBER										28	29	LICENSE TYPE					30	CAT			33

REPORT
SOURCE

L 6 0 5 0 0 0 6 4 7 0 6 1 4 8 1 3 0 7 0 7 8 1 9
60 61 SOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 2030 on 6/14/81, the steam jet air ejector noble gas activity monitor (RE-15) was

declared inoperable when it failed low. Tech. Spec. 3.3.3.11, in part, requires RE-15

to be operable. Tech. Spec. 3.3.3.11 action statement requirements were met. Health/

| safety of the public was not affected.

SYSTEM CODE M C 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14				COMP. SUBCODE E 15		VALVE SUBCODE Z 16					
EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 2 5 23 24 25 26		OCCURRENCE CODE 0 3 27 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32									
ACTION TAKEN B 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41		NPRO-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER N 25 43		COMPONENT MANUFACTURER N 1 2 0 44 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The event was caused by a faulty connection at the detector. This condition was

corrected and following successful testing, RE-15 was returned to service at 1450 on

6/15/81.

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
1	5	G	0	0	0	NA	A	Operator Observation			
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	Z	NA							
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	Z		NA				
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0			NA				
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z					NA				
PUBLICITY		ISSUED		DESCRIPTION		8107310370 810707 PDR ADDCK 05000364 S PDR		NRC USE ONLY			
2	0	N				NA					

NAME OF PREPARER

W. G. Hairston, III

PHONE (205) 899-5156