

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

REPORT SOURCE L 5 0 5 0 0 0 3 4 8 7 0 6 1 3 8 1 3 0 7 0 7 8 1 9  
 80 81 DOCKET NUMBER 88 89 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 0730 on 6/13/81, the "A" train service water loop was declared inoperable when it was  
 0 3 determined that the emergency recirculation valve (v539) would not operate. Tech. Spec.  
 0 4 3.7.4 requires two independent service water loops to be operable. Tech. Spec. 3.7.4  
 0 5 action statement requirements were met. Health/safety of the public was not affected.  
 0 6  
 0 7  
 0 8  
 0 9

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
 W A 11 X 12 Z 13 V A L V E X 14 B 15 D 16  
 9 10 11 12 13 14 15 16 17 18 19 20  
 17 LEAD REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
 8 1 0 4 5 0 3 L 0  
 21 22 23 24 25 26 27 28 29 30 31 32  
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
 A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 X 9 9 9 9  
 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The event was caused by a blown control circuit fuse. The fuse was replaced and the  
 1 1 valve successfully tested. The "A" train service water loop was then returned to  
 1 2 service at 1430 on 6/13/81. This is considered to be an isolated occurrence.  
 1 3  
 1 4

1 5 FACILITY STATUS IS POWER OTHER STATUS (20) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)  
 E 23 1 0 0 29 NA A 31 Operator Observation  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
 1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
 Z 33 Z 34 NA NA  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
 1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  
 0 0 0 37 Z 38 NA  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
 1 8 PERSONNEL INJURIES NUMBER DESCRIPTION (41)  
 0 0 0 40 NA  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
 1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)  
 Z 42 NA  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60  
 2 0 PUBLICITY ISSUED DESCRIPTION (45) NAME OF PREPARER W. G. Hairston, III  
 N 44 NA 8107310384 810707 PDR ADOCK 05000348 S PDR  
 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

NRC USE ONLY

PHONE: (205) 899-5156