NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N C M G S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 9 (7) | 0 5 2 2 8 1 (8) | 0 6 0 5 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 5, initial fuel loading, radiation monitor EMF-49 was
03 discovered inoperable during a liquid waste release. The release was
04 terminated, however, it was restarted inadvertantly prior to the completion
05 of the analysis of the sample from the tank. This violated an Action
06 Statement and is reportable per T.S. 6.9.1.12(b). Since there is only
07 new, nonirradiated fuel in the core, the health and safety of the public
08 were not affected.

09 SYSTEM CODE: M A (11) | CAUSE CODE: A (12) | CAUSE SUBCODE: B (13) | COMPONENT CODE: 1 N S T R U (14) | COMP. SUBCODE: E (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 — SEQUENTIAL REPORT NO. 0 8 3 — OCCURRENCE CODE 0 1 — REPORT TYPE T — REVISION NO. 0

ACTION TAKEN: L (18) | FUTURE ACTION: G (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: Y (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: L (25) | COMPONENT MANUFACTURER: G 0 6 3 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A technician misinterpreted directions from the supervisor and a
11 procedure was not followed as needed. The malfunctioning monitor is to be
12 repaired and the procedures will be revised in order to prevent a
13 reoccurrence.
14

15 FACILITY STATUS: X (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): Mode 5 | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Personnel Observation

16 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

19 LOSS OF OR DAMAGE TO FACILITY (43) — TYPE: Z (42) | DESCRIPTION: NA

20 PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

NAME OF PREPARER: R. W. Ouellette PHONE: (704) 373-7530

8107310464 810605
PDR ADOCK 05000369
S PDR