

OFFICIAL COPY

1750 Chestnut Street Tower II

July 16, 1981

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE  
REPORT SQRO-50-327/81058 REVISION 1

The enclosed report is a supplement to my letter dated June 9, 1981, concerning the setpoint for steam generator level bistable 1-LS-3-38B being outside the acceptable technical specification limits. This event placed the unit in action statement 7 of limiting condition for operation 3.3.1.1 and action statement 16 of limiting condition for operation 3.3.2.2 and is reported under Sequoyah unit 1 Technical Specification 6.9.1.13.a.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Green*  
H. J. Green  
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Bill Lavallee  
Nuclear Safety Analysis Center  
Palo Alto, California 94303

NRC Inspector, Sequoyah

IE22  
S/I