

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C M G S 1 2 0 0 - 0 0 0 0 1 0 3 6 9 3 4 1 1 1 1 4 5  
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 54

CON'T  
 0 1 REPORT SOURCE L 6 0 5 0 0 0 1 3 6 9 7 0 5 3 0 8 1 8 0 6 2 5 8 1 9  
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
 0 2 On May 30, 1981 at 2000 hours, Unit 1 was entering Mode 3 from Mode 4. The  
 0 3 S/G "D" Auxiliary Feedwater Flow Rate Instrumentation was pegged high, hence,  
 0 4 the instrument was declared inoperable per Technical Specification 3.3.3.6  
 0 5 which is reportable per Technical Specification 6.9.1.13(b). The inoper-  
 0 6 ability of these instruments would not affect the auxiliary feedwater sys-  
 0 7 tem in providing and maintaining its necessary functions. Therefore, the  
 0 8 health and safety of the public were not affected by this incident.

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
 I D 11 E 12 A 13 I N S T R U 14 T 15 Z 16  
 17 LER/NO REPORT NUMBER 8 1 19 2 0 1 3 L 0  
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
 C 18 C 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 L 25 R B 6 1 9 26  
 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
 1 0 The S/G "D" Auxiliary Feedwater Flow Monitoring Instrumentation became in-  
 1 1 operable due to failed transmitters. One transmitter (Rosemount, Model  
 1 2 1151) was sending a faulty 74 milliamp signal; and another transmitter  
 1 3 (Barton 386A) had burned resistors due to its power supply. Both transmitters  
 1 4 were replaced and calibrated, and the power supply was removed and will be  
 1 5 replaced.  
 1 6 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
 X 28 0 0 0 0 29 Mode 3 A 31 Personnel Observation  
 1 7 ACTIVITY CONTENT AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
 Z 33 Z 34 NA  
 1 8 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
 0 0 0 0 37 Z 38 NA  
 1 9 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
 0 0 0 0 40 NA  
 2 0 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
 Z 42 NA  
 2 1 PUBLICITY ISSUED DESCRIPTION 45  
 N 44 NA

NAME OF PREPARER Phillip B. Nardoci

PHONE: (704) 373-7432

8108030245 810625  
PDR ADCK 05000369  
S PDR