

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
L I C E N S E   C O D E										L I C E N S E   N U M B E R									
R E P O R T   S O U R C E										D O C K E T   N U M B E R									
E V E N T   D E S C R I P T I O N   A N D   P R O B A B L E   C O N S E Q U E N C E S																			
On May 30, 1981 at 2000 hours, Unit 1 was entering Mode 3 from Mode 4 but																			
the S/G "1B" wide range level instrumentation had been pegged high. Hence,																			
the shift supervisor declared the instruments inoperable per Technical Speci-																			
fication 3.3.3.5 which is reportable per Technical Specification 6.9.1.13(b).																			
This was similar to previous LER/RO 81-048/03L-0. Since redundant in-																			
strumentation was available, the health and safety of the public were not																			
affected.																			
S Y S T E M   C O D E										C A U S E   C O D E									
I D										A X									
C A U S E   S U B C O D E										C O M P O N E N T   C O D E									
X										V A L V E X									
L E R / R O   R E P O R T   N U M B E R										E V E N T   Y E A R									
81										81									
A C T I O N   T A K E N										E F F E C T   O N   P L A N T									
Z										Z									
H O U R S										A T T A C H M E N T   S U B M I T T E D									
0000										Y									
C A U S E   D E S C R I P T I O N   A N D   C O R R E C T I V E   A C T I O N S																			
Repair personnel found that the equalizer valve on transmitter 1CFLT5620 had																			
been valved open which resulted in draining of the HP reference leg. It is																			
unknown how the valve was left open. The valve was closed and the re-																			
ference leg filled. The wide range instrumentation was checked for proper																			
operation and declared operable.																			
F A C I L I T Y   S T A T U S										M E T H O D   O F   D I S C O V E R Y									
X										A									
P E R S O N N E L   E X P O S U R E S										D I S C O V E R Y   D E S C R I P T I O N									
NA										Personnel observation									
P E R S O N N E L   I N J U R I E S										L O C A T I O N   O F   R E L E A S E									
NA										NA									
L O S S   O F   O R   D A M A G E   T O   F A C I L I T Y																			
NA																			
P U B L I C I T Y																			
NA																			
N A M E   O F   P R E P A R E R										P H O N E									
Phillip B. Nardoci										(704) 373-7432									

8108030339 810625  
PDR ADJCK 05000369  
S PDR