

USNRC REPORT  
ATLANTIC TELEPHONE REPORT

OFFICIAL COPY

81-062-05L  
81-067-05L 31 MAY 11 A 8:51

FACILITY Brunswick 1 and 2

DOCKET NUMBER

325 - 324

TELECON DATE 5/11/81

TIME 8:15 a.m.

LIC OCC. NO.



INSPECT PER MC

*Dave Mc Guire*

M. Hatcher

CALLED at 8:15 this date

WITH THE FOLLOWING:

SUBJECT: Temporary Loss of Power to Security Systems

On May 11, 1981 at 7:10 a.m. a temporary loss of power occurred while switching from one emergency power buss to another. This loss of power caused the inability to monitor security alarms in the CAS and SAS. The system was back on-line at 7:13 a.m. and fully operational at 7:17 a.m. A written report will be submitted to his office within five (5) days.

A WRITTEN REPORT IS DUE: 5/15/81

AIIS NUMBER:

8108030350 810511  
PDR ADDCK 05000324  
S PDR

*IE29  
5/1/8*