


## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 

0	1	N	J	S	G	S	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	1	7	0	6	0	9	8	1	8	0	7	0	9	8	1	9
60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a turbine generator startup, at 1223 hours, June 9, 1981, Reactor Coolant  
0 3 | system temperature was allowed to decrease to less than 541°F. The decrease in  
0 4 | temperature was due to the overfeeding of the steam generators while attempting to  
0 5 | restore them to the normal operating level. In order to restore temperature,  
0 6 | control rods were withdrawn and the Reactor Coolant System temperature was restored  
0 7 | to greater than 541°F at 1236 hours. Action Statement 3.1.1.4 was entered at 1223  
0 8 | hours and terminated at 1236 hours.

SYSTEM CODE R B 11		CAUSE CODE A 12		CAUSE SUBCODE A 13		COMPONENT CODE Z Z Z Z Z 14				COMP SUBCODE Z 15		VALVE SUBCODE Z 16	
7 8		9 10		11		12		13		18		19 20	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 4 2 23 24 25 26		OCCURRENCE CODE / 27		REPORT TYPE L 28 29		REVISION NO. 0 30 31 32			
ACTION TAKEN H 18		FUTURE ACTION H 19		EFFECT ON PLANT B 20		SHUTDOWN METHOD C 21		HOURS 0 0 0 0 22 37 38 39 40		ATTACHMENT SUBMITTED Y 23		NPRD-4 FORM SUB Y 24	
33 34		35		36		37 38 39 40		41 42		43		44 45 46 47	
PRIME COMP. SUPPLIER Z 25		COMPONENT MANUFACTURER Z Z Z Z 26											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Reactor Coolant System temperature was restored by withdrawing control rods. The

1 1 personnel involved in the startup were counseled on plant operating procedures and

1 2 practices.

1 3

1 4

7 8 9  
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)  
1 5 B (28) 0 0 6 (29) N/A A (31) Operator Observation  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 33 10 Z 34 NA

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
1	7	37	38 NA

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	40	NA

8 9		11 12	
TYPE		DESCRIPTION	
1	9	2	42 NA

7 8 9 10

PUBLICITY

ISSUED DESCRIPTION (45)

2 0 N (44) NA

68 69 80

NRC USE ONLY

PHONE: 609-935-0998