

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 34

CONT  
01 REPORT SOURCE 1 5 0 5 0 0 0 3 6 9 7 0 4 1 6 8 1 8 0 5 1 6 8 1 9  
7 8 9 DOCKET NUMBER 50 51 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, initial fuel loading, cold leg injection accumulator  
03 A was declared inoperable due to a high level alarm. The  
04 contained volume was above the limits required by T.S. 3.5.1.1 and is  
05 therefore reportable per T.S. 6.9.1.13(b). Since there is only new  
06 fuel in the core, the health and safety of the public were not affected.  
07  
08

09 SYSTEM CODE 11 CAUSE CODE 12 CAUSE SUBCODE 13 COMPONENT CODE 14 COMP. SUBCODE 15 VALVE SUBCODE 16  
7 8 9 S F E B V A L V E X C A  
17 LER/RO REPORT NUMBER 21 EVENT YEAR 22 SEQUENTIAL REPORT NO. 23 OCCURRENCE CODE 24 REPORT TYPE 25 REVISION NO. 26  
18 B 19 Z 20 Z 21 Z 22 0 0 0 23 0 1 3 24 L 25 0  
13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 38 NPRO-4 FORM SUB. 39 PRIME COMP. SUPPLIER 40 COMPONENT MANUFACTURER  
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 B Z Z Z 0 0 0 Y N L W 0 3 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cold leg accumulator A discharge check valves were leaking.  
11 This allowed reactor coolant system water to fill the accumulator  
12 to above its alarm setpoint. The valves will be repaired and retested.  
13  
14

15 FACILITY STATUS 28 % POWER 29 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32  
7 8 9 X 0 0 0 Mode 3 B Routine Surveillance  
16 ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
7 8 9 Z Z NA NA  
17 PERSONNEL EXPOSURES 37 NUMBER 38 TYPE 39 DESCRIPTION 40  
7 8 9 0 0 0 Z NA  
18 PERSONNEL INJURIES 41 NUMBER 42 DESCRIPTION 43  
7 8 9 0 0 0 NA  
19 LOSS OF OR DAMAGE TO FACILITY 44 TYPE 45 DESCRIPTION 46  
7 8 9 Z NA  
20 PUBLICITY 47 ISSUED DESCRIPTION 48  
7 8 9 N NA S  
8108030388 810515  
PDR ADOCK 05000369  
S PDR

NAME OF PREPARER R.W. Ouellette  
PHONE: (704) 373-7530