

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	F	L	S	L	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
		LICENSE CODE							LICENSE NUMBER											LICENSE TYPE						ST CAT ID			

CCN'T

REPORT SOURCE 01 05 00 03 35 7 05 28 8 1 3 06 29 8 1 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During 100% power operation while performing ESF Channel Functional Test
0 3 Steam Generator Pressure Channel MC setpoint was found to be less than
0 14 specified by Tech Spec 3.3.2 Table 3.3-4. The setpoint was immediately ad-
0 5 justed to the correct value. There have been two previous occurrences of
0 5 SG pressure setpoint drift. (Ref LER 76-17 and 77-25). There were no
0 7 consequences to the health and welfare of the public.

0 9		3 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP SUBCODE		VALVE SUBCODE	
0 9		6		I B 11		X 12		Z 13		Z Z Z Z Z 14				Z 15		Z 16	
7		5		9 10		11		12		12 13 14 15 16				17		18	
17		LSR/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
17		8 1		0 2 9		0 3		L		0							
21		22		23		24		25		26		27		28		29	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPD-4 FORM 5-B		PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER	
E 13		X 14		Z 20		Z 21		0 0 0 0		N 22		N 23		Z 24		Z Z Z Z 25	
33		34		35		36		37		40		41		42		43	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause for SG Channel MC pressure setpoint drift could not be
11 determined. The setpoint was adjusted to the correct value and
12 I&C is continuing to monitor periodically to detect any future
13 setpoint drift.

1	4													
7	8	9												
FACILITY STATUS			% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION (32)		
1	5	E	(23)	1	0	0	(29)	NA	B	(31)	OBSERVED WHILE FUNCTIONAL TESTING			
13	14	15	16	17	18	19	20	21	22	23	24	25	26	27

ACTIVITY CONTENT
RELEASED OF RELEASE

1 5 2 13 7 24

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (26)

NA

PERSONNEL EXPOSURES		TYPE		DESCRIPTION
NUMBER				
17	000	(17)	Z	(19) NA

PERSONNEL NUMBER		DESCRIPTION
1	4	NA

		LOSS OF OR DAMAGE TO FACILITY		
TYPE		DESCRIPTION		
1	3	Z	(12)	NA

3 2 10 PUBLICITY
 2 0 N 11 DESCRIPTION 45 NA
 NRC USE ONLY

NAME OF PREPARER P. L. Pace

240NE (305) 552-3654