

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 6 0 6 8 1 3 0 7 0 1 8 1 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 At 2320 on 6/6/81, while performing FNP-0-STP-1.0 (Operations Daily and Shift Surveillance

0 3 Requirements), the overtemperature-delta temperature instrumentation loop associated with

0 4 TI432C was declared inoperable when its trip setpoint failed to meet the tolerance

0 5 requirements of the test. Tech. Spec. 3.3.1, in part, requires TI432C to be operable.

0 6 Tech. Spec. 3.3.1 action statement requirements were met. Health/safety of the public

0 7 was not affected.

0 8 9 80

0 9 SYSTEM CODE 11 CAUSE CODE 12 CAUSE SUBCODE 13 COMPONENT CODE 14 COMP. SUBCODE 15 VALVE SUBCODE 16

17 LER/RO REPORT NUMBER 18 EVENT YEAR 19 SEQUENTIAL REPORT NO. 20 OCCURRENCE CODE 21 REPORT TYPE 22 REVISION NO.

ACTION TAKEN 23 FUTURE ACTION 24 EFFECT ON PLANT 25 SHUTDOWN METHOD 26 HOURS 27 ATTACHMENT SUBMITTED 28 NRC-4 FORM SUB. 29 PRIME COMP. SUPPLIER 30 COMPONENT MANUFACTURER

0 E 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 N 25 W 1 2 0 26

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 1 This occurrence is attributable to an out of adjustment gain potentiometer. The potent-

1 2 iometer was adjusted, proper operation verified and the channel was returned to service

1 3 at 0207 on 6/7/81.

1 4 9 80

1 5 FACILITY STATUS 28 % POWER 29 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32

0 E 28 0 4 0 29 NA B 31 Performance of Surveillance Test

1 6 ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

0 Z 33 Z 34 NA NA

1 7 PERSONNEL EXPOSURES 37 NUMBER 38 TYPE 39 DESCRIPTION 40

0 0 0 37 Z 38 NA

1 8 PERSONNEL INJURIES 41 NUMBER 42 DESCRIPTION 43

0 0 0 40 NA

1 9 LOSS OF OR DAMAGE TO FACILITY 44 TYPE 45 DESCRIPTION 46

0 Z 42 NA

2 0 PUBLICITY 47 ISSUED 48 DESCRIPTION 49

0 N 44 NA 8108030397 810701 PDR ADDOCK 05000364 PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156