

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

CON'T

REPORT SOURCE 60 61 0 5 0 - 0 3 2 4 7 0 6 0 9 8 1 8 0 6 2 9 8 1 9

DOCKET NUMBER 68

EVENT DATE 69

REPORT DATE 74 75

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing unit load changes after a normal reactor startup, 2A Reactor Recir-

0 3 | culation Pump motor generator (MG) tripped. Following a reset of the MG trip signals,

0 4 | the pump could not be started because the MG set generator field breaker would not

0 5 | close. 2A Reactor Recirculation Pump was declared inoperable in accordance with

0 6 | technical specifications. This event did not affect the health and safety of the

0 7 | public.

08 | Technical Specifications 3.4.1.1, 6.9.1.9B

SYSTEM CODE C B 11		CAUSE CODE X 12		CAUSE SUBCODE X 13		COMPONENT CODE Z Z Z Z Z Z 14						COMP. SUBCODE Z 15		VALVE SUBCODE Z 16			
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 5 2 24 25 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32							
ACTION TAKEN B 18		FUTURE ACTION X 19		EFFECT ON PLANT A 20		SHUTDOWN METHOD A 21		HOURS 0 0 1 2 22 37 38 39 40		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER G 0 8 0 26 44 45 46 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A visual inspection of the MG field windings and an electrical check of the MG trip
1 1 | circuitry did not reveal the cause of the 7 trip. Dirty electrical contacts were
1 2 | found in the field breaker closure circuitry which prevented a pump restart but
1 3 | which would not have caused the initial trip. The contacts were cleaned and on
1 4 | 6-10-81 the MG was started and the pump was returned to operation.

8 9
FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 F 0 1 3 NA A Operational Event

2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 2 33 10 34 NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7	0	0	0	(37)	Z	(38)	NA		

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
00C	NA

7		8	9	11		12		
TYPE				DESCRIPTION				
1	9	Z	42	NA				

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (4F) 8108030398 810629
2 0 N 44 NA PDR ADOCK 05000324
S PDR
NRC USE ONLY
68 69 70

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521