



435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

July 29, 1981

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555



Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Change Request No. 64 to Operating License

Gentlemen:

Enclosed are three (3) originals and thirty-seven (37) copies of a proposed change to the Beaver Valley Power Station Technical Specification Appendix A. This proposed Technical Specification change requests that Table 3.6-1 be modified as shown in the attachment to this letter. The proposed Table 3.6-1 reflects that the Containment Purge Exhaust and Containment Purge Supply damper isolation times are not applicable in Modes 1 through 4.

Safety Evaluation

The purpose of this change is to more clearly define the applicable modes of operation for the Containment Purge Exhaust and Containment Purge Supply dampers. The dampers are required to be operable in Modes 5 & 6 to mitigate the consequences of a fuel handling accident. During Modes 1 through 4, the dampers are shut and de-energized.

The OSC and ORC has reviewed this proposed change to the Technical Specifications and have determined that there are no unreviewed safety implications associated with this change and that this change does not constitute an unreviewed safety question.

We have determined that this change is a Class III Amendment and a check for \$4,000 will be submitted under separate cover in accordance with 10CFR 170.22.

Very truly yours,

J. J. Carey
Vice President, Nuclear

8108040176 810729
PDR ADOCK 05000334
PDR
P

Aool
5/11

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Change Request No. 64 to Operating License
Page 2

cc: Mr. D. A. Beckman, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

COMMONWEALTH OF PENNSYLVANIA)

COUNTY OF BEAVER)

SS:

On this 29th day of July, 1981, before me, Judith D. Anthony, a Notary Public in and for said Commonwealth and County, personally appeared J. J. Carey, who being duly sworn, deposed, and said that (1) he is Vice President of Duquesne Light, (2) he is duly authorized to execute and file the foregoing Submittal on behalf of said Company, and (3) the statements set forth in the Submittal are true and correct to the best of his knowledge, information and belief.

Judith D. Anthony
Notary Public

JUDITH D. ANTHONY, Notary Public
Shippingport Borough, Beaver Co., Pa.
My Commission Expires Dec. 12, 1983