

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

03 | equipment drain flow integrator, 2-G16-Q-K603, was continuously counting with no

04 pumps running. This event did not affect the health and safety of the public.

0	5
---	---

06

Technical Specifications 3.4.3.1b, 6.9.1.9b

0	8	
---	---	--

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP SUBCODE		VALVE SUBCODE					
C	I	E	E	I	N	S	T	R	U	Q	Z						
9	10	11	12	13	14	15	16	17	18	19	20						
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
8	1	0	6	7	0	3	L	0									
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NFRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E	Z	Z	Z	0	0	0	N	Y	N	G	0	8	0				
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Instrument drift of the integrator, Model No. 561, caused this event. The integrator
---	---	--

111 | was calibrated and was returned to service. In addition, the signal response of the

integrator flow recorder, 2-G16-FY-K602, was checked with no problems found. A

1 3 | check of plant documentation showed this is an isolated event; therefore, no further

1 4 | corrective action is required.

8 9
FACILITY STATUS 30
% POWER OTHER STATUS
0 7 5 29 NA
METHOD OF DISCOVERY 31
DISCOVERY DESCRIPTION 32
Operator Surveillance
45 46 80

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 2 33 34 NA
45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
180040	NA

8		9		11		12		
LOSS OF OR DAMAGE TO FACILITY				(43)				
TYPE		DESCRIPTION						
1	9	Z	(42)	NA				

7 8 9 10
 PUBLICITY
 ISSUED DESCRIPTION (45)
 (2) (U) (N) (44) NA
 8108040213 810722
 PDR ADOCK 05000324
 S PDR
 NRC USE ONLY