

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 S I C I N E E 1 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

0 1 REPORT SOURCE L 5 0 5 0 1 0 0 2 6 9 7 0 1 6 2 2 8 1 1 8 0 1 7 2 2 8 1 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On June 22, 1981, startup transformer CT-1 locked out for unknown reasons.  
0 3 During the time period that CT-1 was locked out, back-up power was verified  
0 4 available from Keowee-1. Thus, the health and safety of the public were  
0 5 not affected by this incident.  
0 6  
0 7  
3 8

0 9 SYSTEM CODE E B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE T R A N S F 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

17 LER/RO REPORT NUMBER 8 1 21 SEQUENTIAL REPORT NO. 0 0 9 24 OCCURRENCE CODE 0 3 27 REPORT TYPE L 30 REVISION NO. 0 32  
ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 APPROX. FORM SUB. N 24 PRIME COMP. SUPPLIER L 25 COMPONENT MANUFACTURER G O 8 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The reason for CT-1 locking out is not known. The CT-1 transformer and buss  
1 1 work were checked for faults, and the protective relaying was checked for  
1 2 malfunction prior to returning control to Operations. A more complete check  
1 3 will be performed on the CT-1 transformer and switchgear during the current  
1 4 Unit 1 refueling outage.

1 5 FACILITY STATUS E 28 % POWER 0 9 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 6 ACTIVITY CONTENT Z 33 RELEASED OR RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 9 LOSSES OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

NRC USE ONLY

NAME OF PREPARER J. L. Jones

PHONE: (704) 373-8197