

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 56

CONF 01
7 8
REPORT SOURCE 1 5 0 5 0 0 0 3 6 9 7 0 7 1 0 8 1 3 0 7 2 4 8 1 9
7 8 DOCKET NUMBER 55 56 EVENT DATE 74 75 REPORT DATE 86

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, during the replacement process of a defective resistance tempera
03 ture detector (RTD) on the "A" loop RTD manifold, a technician opened the manifold's
04 inlet valve causing steam to blow out the open vent and drain valves. This re-
05 lator coolant leak possibly violated Tech. Spec. 3.4.7.1 and is reportable per
06 TS 6.9.1.12(G). Because of the actions of the positive displacement pump, the
07 availability of all the safety injection pumps had they been needed, and only new
08 fuel in the core, the health and safety of the public were not affected.

09
7 8
SYSTEM CODE 5 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP SUBCODE 14 VALVE SUBCODE 15
C R 11 A 12 C 13 V A L V E X 14 F 15 D 16

17 LER/RO REPORT NUMBER 21 22
8 1
23
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
Y H 7 7 0 0 0 0 0 Y N L Z 9 9 9
13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The IAE technicians misunderstood the instructions of their supervisor and at-
11 tempted to do work for which they were neither trained or qualified, and were
12 without proper procedures. The leak was isolated by closing the manifold vent
13 and drain valves. IAE technicians will receive special instruction on which
14 valves they are allowed to operate and the entire tagging procedure.

15
7 8
FACILITY STATUS 9 POWER 10 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32
X 28 0 0 0 29 Mode 3 A 31 Personnel Observation

16
7 8 9 ACTIVITY CONTENT 10 AMOUNT OF ACTIVITY 33 LOCATION OF RELEASE 35
Z 33 2 34 NA NA

17
7 8 9 PERSONNEL EXPOSURES 10 TYPE 11 DESCRIPTION 39
0 0 0 37 2 38 NA

18
7 8 9 PERSONNEL INJURIES 10 NUMBER 11 DESCRIPTION 41
0 0 1 40 Steam burn

19
7 8 9 LOSS OF OR DAMAGE TO FACILITY 10 TYPE 11 DESCRIPTION 43
2 42 NA

20
7 8 9 PUBLICITY 10 ISSUE 11 DESCRIPTION 45
N 44 NA

21
7 8 9 NRC USE ONLY 46 47 48 49 50