

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

T N S N P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5
 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT NO.

REPORT SOURCE L 6 0 5 1 0 0 0 3 2 7 7 0 6 2 6 8 1 9 0 7 2 4 8 1 9
 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

Unit 1 in Mode 4 with RCS T avg $\approx 300^{\circ}\text{F}$ and Pressure ≈ 1000 psig. The Service Bldg. Vent monitor (0-RM-90-132) was declared inoperable due to failure of sampling pump, which resulted in placing the unit into action statement 42 of LCO 3.3.3.10. Manual grab sampling was initiated at 1636 (CDT). There was no effect upon public health and safety. Previous occurrences - 1 (Reference: SQRO-50-327/80053).

SYSTEM CODE M B 11 CAUSE CODE E 12 CAUSE SUBCODE F 13 COMPONENT CODE P U M P X X 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16
 LER/RO REPORT NUMBER 8 1 21 22 SEQUENTIAL REPORT NO. 0 7 4 23 24 25 26 OCCURRENCE CODE 0 3 27 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
 ACTION TAKEN A 18 33 FUTURE ACTION Z 19 34 EFFECT ON PLANT Z 20 35 SHUTDOWN METHOD Z 21 36 HOURS 0 0 0 0 22 37 38 39 40 ATTACHMENT SUBMITTED N 23 41 42 NPDD-4 FORM SUB. N 24 43 PRIME COMP. SUPPLIER L 25 44 45 COMPONENT MANUFACTURER G 0 6 3 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

The radiation monitor sample vacuum pump failed due to normal wear. The spare sample pump was valved in and the monitor placed back in service at 1530 (CDT) on 6/30/81. The defective pump was replaced on 7/15/81.

FACILITY STATUS C 28 9 10 11 12 13 OTHER STATUS NA 30 44 METHOD OF DISCOVERY A 31 45 46 DISCOVERY DESCRIPTION Operator observation 32 80
 ACTIVITY CONTENT Z 33 9 10 11 12 13 RELEASED OF RELEASE Z 34 9 10 11 12 13 AMOUNT OF ACTIVITY NA 35 44 45 LOCATION OF RELEASE NA 36 80
 PERSONNEL EXPOSURES NUMBER 0 0 0 37 11 12 13 TYPE Z 38 11 12 13 DESCRIPTION NA 39 80
 PERSONNEL INJURIES NUMBER 0 0 0 40 11 12 13 DESCRIPTION NA 41 80
 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 9 10 11 12 13 DESCRIPTION NA 43 80

PUBLICITY N 44 9 10 11 12 13 DESCRIPTION NA 45 80
 ISSUED N 44 9 10 11 12 13 DESCRIPTION NA 45 80

Name of Preparer: D. P. Roberts/M. R. Harding

Phone: (615) 842-8317

NRC USE ONLY