

# DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

July 31, 1981

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief  
Licensing Branch No. 4

Re: McGuire Nuclear Station  
Docket Nos. 50-369, 50-370



Dear Mr. Denton:

Duke Power Company has discussed the matter of training and qualification of Shift Technical Advisors (STA's) with the NRC Staff over the course of the McGuire licensing review process. As a result Duke proposed and the staff accepted the use of individuals holding Senior Reactor Operator (SRO) licenses as STA's. This concept was implemented and has been in effect since January, 1981 during those plant modes in which an STA is required.

Recently, the Shift Supervisors and Assistant Shift Supervisors (all of who hold SRO licenses) have been working overtime on a fairly regular basis to accommodate vacation, sickness and training requirements. To alleviate this situation it is Duke Power Company's intention to utilize degreed engineers as STA's. Engineers selected for this position would receive the same STA training that the SRO licensed operators receive. This matter was discussed with Mr. Larry Crocker from the Licensee Qualifications Branch and he indicated that this was an acceptable approach to satisfy the STA requirement. This letter is to confirm this discussion with Mr. Crocker and to document our intended course of action.

If you have any questions regarding this matter, we will be glad to discuss them with you.

Very truly yours,

*William O. Parker, Jr.*

William O. Parker, Jr. *By [Signature]*

GAC:krh

cc: M. J. Graham  
Resident Inspector  
McGuire Nuclear Station

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

8108070093 810731  
PDR ADCK 05000369  
V PDR

*Boo1  
5/10*