

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 F L S L S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T

0 1 REPORT SOURCE L 0 5 0 0 0 3 3 5 7 0 7 0 1 8 1 3 0 7 3 0 8 1 9

DOCKET NUMBER 50 51 EVENT DATE 68 69 REPORT DATE 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During 100% power operation. MD containment pressure transmitter failed

0 3 intermittently. The power supply was tested and was found to be

0 4 satisfactory. Action was taken in accordance with T. S. 3. 3. 2. 1. and

0 5 3.3.1.1. and the channel (ESFAS and RPS) was placed in bypass. The trans-

0 6 mitter was replaced with a spare and the channel was returned to service.

0 7 There was one previous LER of this type (81-21).

0 8

0 9

SYSTEM CODE I E 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE T 15 VALVE SUBCODE Z 16

LER/RO REPORT NUMBER 17 EVENT YEAR 8 1 SEQUENTIAL REPORT NO. 0 3 6 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN C 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NRC-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER F 1 2 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The spare transmitter (Fischer-Porter, model 50EN1071BCXANS, serial

1 1 7112A5510A17) was used to replace the original transmitter (A15). The

1 2 original transmitter's oscillator and force motor were replaced.

1 3

1 4

FACILITY STATUS E 23 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED DESCRIPTION N 44 NA 45

NAME OF PREPARER Paul L. Pace PHONE (305) 552-3654

NRC USE ONLY