

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	T	N	S	N	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
0	1	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	31	CAT		34

REPORT SOURCE L 6 0 5 0 0 0 3 2 7 7 0 7 1 9 8 1 8 0 7 3 1 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 7 Unit 1 in Mode 3 with RCS temperature and pressure at 537°F and 2235 psig. During
0 3 performance of a linkage interlock test on the lower containment personnel access.
0 4 lock, the inner door was allowed to slam and bounce back. The latch closed blocking
0 5 the door ajar. The outer door was then opened violating containment integrity per
0 6 technical specification 3.6.1.3. There was no effect upon public health or safety.
0 7 Previous Occurrences - 2. (Reference: SQRO-50-327/80113 and 80116).

0 8 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0 9		S A (11)		E (12)		B (13)		P E N E T R (14)				A (15)		Z (16)	
8		9 10		11		12		13 14 15 16 17 18				19		20	
(17) LER/RO REPORT NUMBER		EVENT YEAR				SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.	
8 1		21 22		23		24 25 26		27 28 29				30 31		32	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		PRIME COMP. SUPPLIER	
E (18) Z (19)		33 34		Z (20)		Z (21)		0 0 0 0 (22)				N (23)		L (25)	
35		36		37		38 39 40				41		42		43	
44		45		46		47				48		49		50	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (21)

- 0 Doors were properly closed within 5 seconds. Excessive slack in the door operating
- 1 linkage allowed the door to bounce open enough to allow the latch to block it open.
- 2 The linkage was adjusted to prevent the door from bouncing. An instruction has been
- 3 prepared and is being implemented to periodically check and adjust the slack in the
- 4 operating linkage. Maintaining this adjustment should prevent future occurrences.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
5	G	28		29	NA	A	31	Personnel Observation	32
8	9	10	11	12	13	44	45	46	80

ACTIVITY CONTENT
RELEASED OF RELEASE

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES				DESCRIPTION	
NUMBER	TYPE				
7	0	0	17	Z	NA

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
8 0 0 0 41	NA

LOSS OF OR DAMAGE TO FACILITY		(43)
TYPE	DESCRIPTION	
(7) (Z) (42)	NA	

10 PUBLICITY (45)
ISSUED DESCRIPTION (44) NA
NRC USE ONLY

NRC USE ONLY ✓

8108100331 810731
PDR ADOCK 05000327
S PDR

Phone: (615) 842-8317