

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT  
SOURCE

L	6	0	5	0	0	0	2	6	7	7	0	6	1	6	8	1	8	0	7	1	6	8	1	9
60	61	DOCKET NUMBER										68	EVENT DATE					74	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During a fire drill, it was discovered that one of the Control Room exhaust dampers

03 would not close. This is a degraded mode of LCO 4.10.1 and reportable per Fort St.

0	4	Vrain Technical Specification AC 7.5.2(b)2. No accompanying occurrence. No effect
---	---	---

05 on public health or safety. Similar occurrence RO 78-31.

0	6
---	---

0	7	
---	---	--

08 \_\_\_\_\_

8 9

0 9

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

A A 11 X 12 X 13 V A L V E X 14 L 15 D 16

9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER 
 EVENT YEAR 
 REPORT NO. 
 CODE 
 TYPE 
 NO.

ACTION TAKEN (X) 18 FUTURE ACTION (Z) 19 EFFECT ON PLANT (Z) 20 SHUTDOWN METHOD (Z) 21 HOURS (0 0 0 0) 22 ATTACHMENT SUBMITTED (Y) 23 NPD-4 FORM SUB. (N) 24 PRIME COMP. SUPPLIER (A) 25 COMPONENT MANUFACTURER (P 0 1 4) 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The Control Room kitchen and bathroom exhaust damper was stuck in the open position.

111 The damper handjack was used to free and exercise the damper. When retensioned, the

damper operated properly. Visual inspection indicated some accumulation of dust on

1 3 | damper vanes. A preventive maintenance program is to be developed to inspect and

clean the damper vanes. Damper is a parallel type with a pneumatic piston contromatic operator.<sup>80</sup>

operator.<sup>80</sup>

1 5 H 28 0 0 0 19 N/A A 31 Operator Observation

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  
1 6 2 33 2 34 N/A

LOCATION OF RELEASE (36)  
N/A

PERSONNEL EXPOSURES		TYPE		DESCRIPTION	
NUMBER					
1	7	0	0	0	(37) Z (38) N/A

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
0 0 G (40)	N/A

[illegible]

7 8 9 10  
PUBLICITY (45)  
ISSUED DESCRIPTION (45)  
1 N/A  
8108110128 810716  
PDR ADDCK 05000267  
S PDR  
NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER

PHONE: (303) 785-2224