

PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 • DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

July 6, 1981
Fort St. Vrain
Unit No. 1
P-81182

Mr. Karl V. Seyfrit, Director
Nuclear Regulatory Commission
Region IV
Office of Inspection and Enforcement
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76012



Dear Mr. Seyfrit:

This letter confirms the telephone conversations on July 3rd and 6th, 1981 between Mr. C.H. Hackney of your staff and Mr. H.W. Hillyard of the Fort St. Vrain staff, relative to your ENS Specifications and Upgrade letter dated June 19, 1981. The information given by Hillyard to Hackney was as follows:

Support Request (NRC):

"Timely access for telephone company representatives to make a site survey and subsequently for installing station packages for the upgrade."

Response (PSC):

The only delay would be to complete necessary security access requirements. Several local Mountain Bell repairmen are badged for the necessary areas and would receive immediate unescorted access during regular working hours, 7:30 a.m. to 4:30 p.m., Monday through Friday. Access for other work hours can be arranged by advance notice to the Lead Security Officer, (303) 785-2226, ext. 298.

Unbadged Mountain Bell personnel can be admitted as escorted visitors; badged Mountain Bell personnel may act as escorts. We request 24 hours advance notification of any personnel for whom we are requested to supply an escort. The request may be directed to the Lead Security Officer.

Support Request:

"Power for the station packages."

IEO/
S
1/1

Response:

Power (120V AC 60 Hz), can be supplied from instrument bus no. 3. Power is interruptible in the event of a loss of all outside power, but normally returns, supplied by emergency diesel generator backup after a delay of approximately one minute. The emergency diesel generator supply is provided to carry the safe shutdown loads as described in our Final Safety Analysis Report, Sections 8.2.3.3 and 8.2.3.5.

Support Request:

"Adequate cable facilities (cable pairs)."

Response:

Present facilities are not adequate to implement the proposed upgrade. A cable pair deficiency exists between the plant and the local Mountain Bell switch facility in Platteville, Colorado. Mountain Bell is currently planning additional facilities estimated to be in service about July, 1982.

Support Request:

"Telecommunications planning personnel to serve as primary contacts during the modification."

Response:

Direct inquiries related to the on site system to Mr. H.W. Hillyard, in care of Public Service Company, 16805 WCR 19 1/2, Platteville, Colorado 80651. Telephone (303) 785-2223 ext. 202.

Direct inquiries related to Mountain Bell equipment off site to Mr. George Douglas, in care of Mountain Bell, P.O. Box 707, Room 610, 999 18th Street, Denver 80201. Telephone (303) 624-1932.

Support Requested:

"A listing of each existing and proposed ENS station location based on generic name (e.g. Control Room, TSC, EOF, etc.), building name and address, room number (NOTE: Stations not identified by the NRC as required may be removed or not installed)"

Response:

ENS Station Location	Address	E=Existing P=Proposed
Control Room	Plant; 16805 WCR 19 1/2, Platteville, CO	E
Shift Supervisors Office	Plant; 16805 WCR 19 1/2, Platteville, CO	E
Temporary TSC	Plant; 16805 WCR 19 1/2, Platteville, CO	E*
Permanent TSC	Technical Support Bldg; 16805 WCR 19 1/2, Platteville, CO	E*
RIS	Site; 16805 WCR 19 1/2, Platteville, CO	E
EOF	PSC Business Office, 323 Denver Ave. Ft. Lupton, CO	P

* "Half tapped" to share one line - ENS Station in temporary center will eventually be removed.

Support Request:

"Indication of any planned station moves or installations to be completed at the time of the ENS modification."

Response:

It is unlikely that either of the changes indicated above would coincide with your planned upgrade installation. These are the only modifications or moves anticipated at this time.

Support Request:

"Indication of any temporary ENS station locations and the expected date and building/room number for relocation to permanent locations."

Response:

Other than those described above, we have no plans to add any temporary or permanent ENS Stations.

Support Request:


"Indication of anticipated problems in meeting a system upgrade start date of approximately August 1, 1981."

Response:

Mountain Bell facilities will not have been expanded by the proposed August 1, 1981 date.

If you require additional explanation or support, please contact telecommunications planning personnel identified above.

Sincerely Yours,



O.R. Lee
Vice President

ORL/kac