

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

August 5, 1981



Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Ms. Adensam:

In the Matter of
Tennessee Valley Authority

) Docket No. 50-328
)

The draft full power license for Sequoyah Nuclear Plant unit 2 requires TVA to demonstrate that a negative pressure in the Auxiliary Building Secondary Containment Enclosure (ABSCE) can be attained. Demonstration of negative pressure in the ABSCE is part of the Sequoyah preoperational test program. This test has been completed; and the ability to attain the necessary negative pressure has been demonstrated.

If you have any questions, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

A handwritten signature in cursive script, appearing to read "L. M. Mills".

L. M. Mills, Manager
Nuclear Regulation and Safety

Sworn to and subscribed before me
this 5th day of August 1981

Paulette H. White

Notary Public

My Commission Expires 9-5-84

Boo/
s
1/0

8108110274 810805
PDR ADOCK 05000328
PDR