

NORTHWEST ENERGY SERVICES COMPANY

P O BOX 1090 • KIRKLAND, WASHINGTON 98033

August 6, 1981
NLN-1

Director of Nuclear Reactor Regulation
Attention: Elinor Adensam, Branch Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Skagit/Hanford Nuclear Project
Docket Numbers 50-522 and 50-523
S/HNP Use of WPPSS Meteorological Data



Dear Ms. Adensam:

This letter confirms the June 24, 1981 telephone conversation between Mr. T. Grebel, of my office, and Mr. M. Mallory on the use of WPPSS Unit 2 meteorological data for the Skagit/Hanford Nuclear Project (S/HNP) ER and PSAR site relocation amendments. It was agreed, during this conversation, that due to: (1) the proximity of the S/HNP to the WPPSS 1, 2 and 4 units; and (2) no significant terrain or other factor differences, the WPPSS Unit 2 meteorological data can be used for the S/HNP ER and PSAR amendments and no specific meteorological tower data is required for the construction permit stage.

If you have any questions on this matter, please call Mr. T. Grebel at (206) 828-7250.

Very truly yours,

J. E. Mecca
J. E. Mecca, Manager
Nuclear Licensing & Safety

cc: Michael Mallory

COO2
S
1/0

8108110339 810806
PDR ADOCK 05000522
A PDR