



**PUBLIC
SERVICE
INDIANA**

S. W. Shields
Senior Vice President -
Nuclear Division

07MB/50 55(e)
0803814003



August 3, 1981
S80-13

Mr. James G. Keppler, Director
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Docket Nos.: STN 50-546
STN 50-547
Construction Permit No.:
CPPR - 170
CPPR - 171

Marble Hill Nuclear Generating Station - Units 1 and 2

Dear Mr. Keppler:

On May 9, 1980, Mr. T. D. Geib of Public Service Company of Indiana, Inc. (PSI) notified your office of a potentially reportable item as required by 10 CFR 50.55(e). This item, which pertains to the operation of centrifugal charging pumps during a high energy line rupture, was described in an interim report to your office dated June 2, 1980.

Westinghouse continues to evaluate a number of possible modifications which will resolve this concern. To date, this evaluation has not been completed. PSI will advise your office of Westinghouse recommendations or will furnish you with a further interim report on or before November 20, 1981.

This letter is intended to fulfill the requirements of an interim report as defined in 10 CFR 50.55(e). If you have any questions on this matter, please feel free to contact me.

Sincerely,

[Signature]
S. W. Shields

JE27
S
110

TDG/mjg

cc: Director of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

E. R. Schweibinz, P. E.

J. J. Harrison

8108110474 810803
PDR ADOCK 05000546
S PDR

P. O. Box 190, New Washington, Indiana 47162

812..289.1000AUG

5 1981