NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

Update Report
Previous Report - 2/18/81

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NCBEP1 (2) | 00-000-00 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000-325 (7) | 121881 (8) | 081381 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine shutdown operations it was discovered that reactor recirculation
03 sample inboard isolation valve, 1-B32-F019, model number T36D-1B, had seat leakage of
04 approximately .25 gpm. The recirculation sample outboard isolation valve, 1-B32-F020,
05 was then closed and deactivated. This event did not affect the health and safety of
06 the public.
07
08 Technical Specifications 3.1.3, 6.9.1.9b

09 | SYSTEM CODE PB (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE VALVEX (14) | COMP. SUBCODE F (15) | VALVE SUBCODE D (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 011 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 1

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER V085 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 F019 was disassembled and examined during the 1981 maintenance outage. Minor scratches
11 on the valve seat were discovered which have been attributed to normal use of the valve.
12 The valve seat was lapped and the valve was reassembled and returned to service. As
13 plant documentation shows that this event is an isolated one, no further corrective
14 action is required or planned.

15 | FACILITY STATUS D (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operational Event

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8108130161 810805
PDR ADOCK 05000325
S PDR

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926