

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 1 2 0 0 - 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT  
01 REPORT SOURCE L 5 0 1 5 0 0 0 0 3 6 9 7 0 1 7 0 8 8 1 1 8 0 1 8 0 7 8 1 9  
7 8 9 DOCKET NUMBER 50 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 While in Mode 3, periodic testing of two steam supply valves determined that  
03 they would not cycle within the required time limit. The turbine driven  
04 auxiliary feedwater pump (AFP) was declared inoperable pursuant to Technical  
05 Specification 3.7.1.2 which is reportable per Technical Specification 6.9.1.13(b).  
06 Even though there were no incidents requiring the use of the AFP's, in addition  
07 to both motor driven AFP's availability, the valves did eventually open making  
08 the turbine driven AFP available also. Thus, the health and safety of the public  
were unaffected.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
H H 11 B 12 A 13 V A L V E X 14 E 15 A 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 1 1 1 4 0 3 L 0  
21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN F 18 Z 19 Z 20 Z 21 0 1 0 0 0 Y 22 N 24 L 25 Z 9 9 9 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 A system redesign to correct a water hammer problem included replacing the  
11 orifice which bleeds off air pressure from each valve with a smaller one,  
12 resulting in a long opening time for the valves. The small orifice was  
13 replaced with one of the original size, and the valves retested.  
14

15 FACILITY STATUS X 28 0 0 0 0 29 Mode 3 30 METHOD OF DISCOVERY B 31 Periodic Test 32 DISCOVERY DESCRIPTION  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

16 ACTIVITY CONTENT Z 33 Z 34 N/A 35 AMOUNT OF ACTIVITY 36 LOCATION OF RELEASE 37  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 PERSONNEL EXPOSURES NUMBER 0 0 0 0 37 TYPE Z 38 DESCRIPTION 39 N/A  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

18 PERSONNEL INJURIES NUMBER 0 0 0 0 40 DESCRIPTION 41 N/A  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 N/A  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

20 PUBLICITY ISSUED N 44 DESCRIPTION 45 N/A  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY  
68 69 70

NAME OF PREPARER Phillip B. Nardoci

PHONE: (704) 373-7432