

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'1

## REPORT

HE PORT 0 5 0 0 0 2 5 9 7 0 7 2 2 8 1 0 0 0 0 7 0 0 2  
DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	4
---	---

SYSTEM CODE M C 11		CAUSE CODE E 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE E 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 4 1 23 24 25 26		OCCURRENCE CODE 0 3 27 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32			
ACTION TAKEN B 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 22 37 38 39 40		ATTACHMENT SUBMITTED Y 23 41	
NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER L 25 43		COMPONENT MANUFACTURER N 3 0 5 44 45 46 47							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1

1

1

1

8108130276 810807  
PDR ADOCK 05000259  
S PDR

Gene Holder

PHONE (205) 729-6134

LER SUPPLEMENTAL INFORMATION

BEFO-50- 259 / 81041 Technical Specification Involved 3.8.B.8

Reported Under Technical Specification 6.7.2.b(2) \*Date due NRC: 8/21/81

Date of Occurrence 7/22/81 Time of Occurrence 0400 Unit 1

Identification and Description of Occurrence:

Operate/test switch on the continuous air monitor (1-RM-90-249) for the turbine building roof exhaust would not operate, rendering the monitor inoperable.

Conditions Prior to Occurrence:

Unit 1 refueling outage.

Unit 2 at 100%.

Unit 3 at 97%.

Action specified in the Technical Specification Surveillance Requirements met due to inoperable equipment. Describe.

None

Apparent Cause of Occurrences:

Equipment malfunction. The operate/test switch was placed in test during SI performance and could not be returned to operate.

Analysis of Occurrence:

There was no danger to the health or safety of the public, no release of activity, no damage to the plant or equipment, and no resulting significant chain of events.

Corrective Action:

The vents and fans were isolated and tagged. The continuous air monitor was repaired and returned to service at 1530 on 7/22/81. This is considered a random event and no recurrence control is required.

Failure Data:

None

Retention: Period - Lifetime; Responsibility - Document Control Supervisor

\*Revision:

