

## Omaha Public Power District

1623 HARNEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

August 7, 1981

Mr. Robert A. Clark, Chief  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactors Branch No. 3  
Washington, D. C. 20555



Reference: Docket No. 50-285

Dear Mr. Clark:

The Commission's letter dated July 10, 1981 transmitted an order confirming Omaha Public Power District's commitments for TMI-related requirements for the Fort Calhoun Station. The confirmatory order accepted District positions detailed in letters to the Commission dated December 12 and 31, 1980; January 6 and 26, 1981; and February 27, 1981. However, additional information has been submitted on two of the tasks that modifies what was committed to in the above letters. The District's review of the above letter also revealed that we failed to provide a schedule for completing the modifications for control room habitability requirements (Task I.I.D.3.4). The additional information related to these tasks is provided below.

In response to Task I.C.1, Accident Procedures, the District's letter to the Commission dated December 31, 1980 committed to participate in the Combustion Engineering Owners Group (CEOG) effort. The CEOG proposed emergency procedure guidelines in response to this task have now been submitted to the Commission by letter dated June 30, 1981 (K. P. Baskin, CEOG Chairman from Southern California Edison, to Mr. Darrell G. Eisenhower). It is the District's understanding that upon the Commission's approval of these guidelines, they must be implemented during the first refueling outage commencing six months after Commission approval. The District expects to meet this schedule.

The EPRI program schedule for testing of safety and relief valves, Task II.D.1, has been substantially delayed. The revised valve testing schedule was provided to the Commission by the Consumers Power Company letter (R. C. Youngdahl to Mr. Harold Denton, dated July 24, 1981). The District as a participant in the EPRI program endorses the revised schedule. The District also fully supports the EPRI position on block valve testing detailed in the July 24, 1981 letter.

8108140159 810807  
PDR ADOCK 05C00285  
P PDR


4046  
510

Mr. Robert A. Clark  
August 7, 1981  
Page Two

In response to Task III.D.3.4, the District conducted an evaluation of accidents that could degrade control room habitability. As a result of this evaluation several needed modifications were identified, as detailed in the District's letter dated January 26, 1981. The District expects to complete these modifications in accordance with the following schedule:

<u>Modification</u>	<u>Scheduled Completion</u>
1. Radiation shielding	1/1/82
2. Instrumentation for detection of airborne iodine radiation in the control room	6/31/83
3. Electrical and mechanical modifications to the HVAC system	6/31/83
4. Instrumentation for monitoring of toxic chemical gases	1/1/84

Sincerely,



W. C. Jones  
Division Manager  
Production Operations

WCJ/KJM/TLP/RWS/jmm

cc: LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, N. W.  
Washington, D. C. 20036