

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	-	0	2	9	3	7	0	7	3	0	8	1	8	0	8	0	5	1	8	1	9
60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80				

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On July 30, 1981, the drywell floor sump unidentified leak rate was calculated to be 5.4 gpm. This is in excess of the Tech. Spec. Section 3.6.6.i limit of 5 gpm. The required reactor shutdown within 24 hours was initiated. A drywell entry was made to determine cause.

SYSTEM CODE C 1 (11)		CAUSE CODE E (12)		CAUSE SUBCODE X (13)		COMPONENT CODE V A L V E X (14)		COMP. SUBCODE E (15)		VALVE SUBCODE D (16)	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 1 (21)		SEQUENTIAL REPORT NO. 0 3 9 (24)		OCCURRENCE CODE / (27)		REPORT TYPE L (30)		REVISION NO. 0 (32)	
ACTION TAKEN B (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT A (20)		SHUTDOWN METHOD B (21)		HOURS 0 0 7 3 (22)		ATTACHMENT SUBMITTED N (23)	
NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER N (25)		COMPONENT MANUFACTURER C 6 6 5 (26)							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A packing leak on "A" Recirc. discharge valve (MO 202-5A) Crane Co. 28 inch Globe

1 1 | Valve was determined to be the cause of this excessive leakage. The packing was

1 2 | replaced, the valve leak tested and after other, unrelated maintenance was

1 3 | completed, the unit was placed in service.

1 4 |

8 9 FACILITY STATUS (30) % POWER OTHER STATUS (31) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 E (28) 0 6 0 (29) N.A. A (31) Operational Event

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) N.A. N.A.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	38	N.A.	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	2	0	0	0	40 N.A.

LOSS OF OR DAMAGE TO FACILITY		(43)
TYPE	DESCRIPTION	
1 9	Z (42)	N.A.

8 9 10
PUBLICITY
ISSUED DESCRIPTION (45) N.A.
2 0 N (44)
NRC USE ONLY