

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	0	7	1	3	8	1	8	0	8	0	7	8	1	9
60	61									68	69						74	75						80
DOCKET NUMBER										EVENT DATE										REPORT DATE				

0 2 | DURING NORMAL OPERATION, STEAM GENERATOR STOP VALVE DUMP VALVE, MRV-241,
0 3 | WAS REMOVED FROM SERVICE. THAT CONSTITUTED AN INOPERABLE STOP VALVE PER
0 4 | T.S. 3.7.1.5. THE REDUNDANT DUMP VALVE, MRV-242, REMAINED OPERABLE. THE
0 5 | ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.
0 6 | THIS WAS THE FIRST OCCURRENCE OF THIS TYPE.

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
0	9	H	B	E		B		V	A	L	V	E	X	P		D	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17		8	1	0	3	0		0	3	L		0					
21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
B		Z		Z		Z		0	G	0	0	N		N		A	
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE VALVE WAS REMOVED FROM SERVICE TO CORRECT SEAT LEAKAGE. THE VALVE PLUG
1 1 WAS MACHINED AND A NEW SEAT RING WAS INSTALLED IN THE FISHER STYLE 657 EAS
1 2 VALVE. SEAT LEAKAGE ON VALVES USED IN THIS TYPE OF SERVICE IS NOT TOTALLY
1 3 PREVENTABLE. NO FURTHER ACTION IS PLANNED.

1 4 _____ 80

8 9
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 E (28) 0 6 0 (29) NA A (31) OPERATOR OBSERVATION

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA (39)				
7	8	9	11	12	13				

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

1 9		Z		42		43	
TYPE		DESCRIPTION					
				NA			

2 0 N 44 NA S PDR 68 69 80

NAME OF PREPARER DAVID G. WIZNER

PHONE: 616-465-5901, EXT. 1037