

UPDATE REPORT - PREVIOUS REPORT DATE 7/10/81
LICENSEE EVENT REPORT

U.S. NUCLEAR REGULATORY COMMISSION

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALBRF1 200-00000-00 341111 45
7 8 9 14 15 25 26 30 57 CAT 58

CONT

01 REPORT SOURCE L 605000259 7062981 8081181 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (16)

02 During refueling outage, reactor water cleanup system inboard primary containment

03 isolation valve 69-1 was ultrasonically inspected on 6/21/81. An indication was

04 observed on the vessel side of the valve weld. (T.S. 3.6.G) A subsequent radio-

05 graph showed no indications. On 6/24/81 a UT inspection by a level II inspector

06 confirmed an indication. There was no danger to the health or safety of the public.

07 Previous similar event: BFR0-50-259/80004.

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
C G 11 X 12 Z 13 Z Z Z Z Z Z 14 Z 15 Z 16

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 1 0 3 7 0 1 X 1

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A 18 Z 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 L 25 Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cause is unknown at this time. The Velan Model 900 lb, 6 inch, SS stainless

11 steel gate valve, rated at 1146 psi at 500 degrees fahrenheit (normal operating

12 pressure 960 psi) was replaced. The indication is acceptable under the summer

13 1978 Addenda to ASME Section XI Code. This is considered a random event and no

14 further recurrence control is required.

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
H 28 0 0 0 29 NA B 31 UT Inspection

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 NA

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA

8108180477 810811
PDR ADOCK 05000259
S PDR

NRC USE ONLY

(205) 729-6134

NAME OF PREPARER Gene Holder

PHONE: