

# TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3380

File # 10115

R. J. GARY  
EXECUTIVE VICE PRESIDENT  
AND GENERAL MANAGER

August 4, 1981

*Mr. Karl V. Seyfrit, Director*

Mr. Karl V. Seyfrit, Director  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

RIV  
Docket Nos. 50-445/IE Bulletin 80-20  
50-446/IE Bulletin 80-20

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
1981-83 2300 MW INSTALLATION  
REVISED RESPONSE TO NRC  
IE BULLETIN 80-20



Dear Mr. Seyfrit:

The CPSES response to IE Bulletin 80-20 is revised as follows:

1. Item 1 of the response: No change
2. Item 2 of the response: No change
3. Item 3 of the response:

	Method of Contact Supervision	Quantity of Switches		
		Unit 1	Unit 2	Common
A.	Rewire contact light per Westinghouse recommendation	56	56	10
B.	Supervision of contacts via existing lights	16	16	0
C.	Installation of resistors to ensure satisfactory minimum current	0	0	10
D.	No rework necessary	2	2	4

If you have any questions, please advise.

Sincerely,

*R. J. Gary*  
R. J. Gary

RJG:tlS

8108180497 810804  
PDR ADOCK 05000445  
Q PDR

IE11  
5/1/8

cc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, D.C. 20555