

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 T N S N P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 56

CON'T

0 1
2 8

REPORT SOURCE L 6 0 5 0 0 0 3 2 7 7 0 7 1 8 8 1 8 0 8 1 4 8 1 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 With Unit 1 in Mode 3 (470°F and 1700PSIG) at 1843 CDT on 7-18-81, level control

0 3 valve 1-LCV-3-164A failed to respond properly while supplying S/G 1 with AFW from

0 4 motordriven pump 1 A-A. The pump was stopped and train 1 A-A was declared

0 5 inoperable placing Unit 1 in action statement "a" of LCO 3.7.1.2. There was

0 6 no effect on public health or safety. No previous occurrences.

0 7

0 8

SYSTEM CODE 09		CAUSE CODE H H		CAUSE SUBCODE E		COMPONENT CODE C K T B K R						COMP. SUBCODE E		VALVE SUBCODE Z					
7 8		9 10		11 12		13 14 15 16 17 18						19 20		21 22					
17 LER/RO REPORT NUMBER		EVENT YEAR 8		SEQUENTIAL REPORT NO. 093		OCCURRENCE CODE 03						REPORT TYPE L		REVISION NO. 0					
21 22		23 24		25 26		27 28 29						30 31		32					
ACTION TAKEN C		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0000						ATTACHMENT SUBMITTED N		PRIME COMP. SUPPLIER L		COMPONENT MANUFACTURER X999	
33 34		35 36		37 38		39 40						41 42		43 44		45 46			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The valve failed to close due to failure of the associated control switch (1-HS-3-
1 1 | 164-A). Inspection of the switch identified that the gears inside the switch had
1 2 | been stripped. The switch was replaced and the valve controls were verified to
1 3 | operate properly. Train 1A-A was declared operable at 1520 CDT on 7/19/81.
1 4 | Unless this problem occurs again, no further action is planned.

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

(1) 5 (28) D (0)(0)(0) NA (30) A (31) Operator Observation

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 3 4

AMOUNT OF ACTIVITY (35)

NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
18	000	(40)	NA

9		11		12	
LOSS OF OR DAMAGE TO FACILITY					
TYPE		DESCRIPTION			
1	9	7	42	NA	

8 9 10
 PURCITY
 ISSUED DESCRIPTION (45)
 2 0 N 44 NA
 NRC USE ONLY

NRC USE ONLY v