

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

August 11, 1981

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/81083

The enclosed report provides details concerning the inoperability of the
"A" train main control room emergency ventilation system. This event
resulted in entering limiting condition for operation 3.7.7.1 and is
reportable under Sequoyah unit 1 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Lopp
J. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)

Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)

Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

NRC Inspector, Sequoyah

IE22
5
1/1

8108200241 810811
PDR ADOCK 05000327
S PDR