

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C B E P 2 00 - 000000 - 000 341111 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CONT

01 REPORT SOURCE L 6050 - 0324 7071481 8081181 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During plant operation while performing the No. 2 Diesel Generator Monthly Load Test,  
03 PT 12.2b, the diesel tripped and locked out due to jacket water temperature exceeding  
04 the trip setpoint of 200°F. This made the diesel unavailable to perform its design  
05 function. This event did not affect the health and safety of the public.  
06  
07  
08 Technical Specifications 3.8.1.1, 6.9.1.9b  
7 8 9 80

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
E E 11 A 12 B 13 V A L V E X 14 B 15 Q 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
8 1 0 6 6 0 3 L 0  
21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
H 18 H 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 G 0 8 0 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A failure to adequately monitor the diesel jacket water temperature after adjusting  
11 the jacket water temperature control valve manual bypass valve, DJW-V196, in order to  
12 raise the jacket water temperature, caused this event. Following this event, the  
13 diesel was restarted and the PT was satisfactorily completed. All auxiliary operators  
14 will be instructed by Shift Foreman to closely monitor diesel operating parameters  
7 8 9 80

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)  
F 28 0 8 9 29 NA B 31 Periodic Test  
7 8 9 10 11 12 13 44 45 46 80

16 RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
Z 33 Z 34 NA NA  
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  
0 0 0 37 Z 38 NA  
7 8 9 10 11 12 13 80

PERSONNEL INJURIES NUMBER DESCRIPTION (41)  
0 0 0 40 NA  
7 8 9 10 11 12 80

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)  
Z 42 NA  
7 8 9 10 80

PUBLICITY ISSUED DESCRIPTION (45)  
N 44 NA  
7 8 9 10 80

8108200320 610811  
PDR ADDOCK 05000324  
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521