

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

August 11, 1981

Mr. J. P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 1
Docket No. 50-369



Dear Mr. O'Reilly:

My letter of July 10, 1981 notified you that all information for a 30-day reportable occurrence (RO-369/81-99), which was originally to be submitted on that date, was not yet available and that the report would be submitted by August 10, 1981. This reportable occurrence concerned technical specification 3.3.3.8, "The radioactive liquid effluent monitoring instrumentation channels shown in table 3.3-12 shall be operable...", which was thought to have been violated on June 11, 1981. The completed investigation determined that the incident is not reportable as a reportable occurrence because it involved the inoperability of EMF-44 (an offsite release monitor), and since no offsite release was made, the plant was not considered to be "operating in a degraded mode" as specified in the reportability requirement (T.S.6.9.1.13(b)).

Very truly yours,


William O. Parker, Jr.

PBN/dsg

cc: Director
Office of Management and Program Analysis
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Bill Lavalee
Nuclear Safety Analysis Center
Post Office Box 10412
Palo Alto, California 94303

Ms. M. J. Graham
Resident Inspector - NRC
McGuire Nuclear Station

IE22
S
1/0