


LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	E	V	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					J0	57	CAT		58

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 3 3 4 7 0 8 0 3 8 1 8 0 8 1 3 8 1 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | The tritium activity in a quarterly composite of weekly grab samples, collected

0 3 | in the Ohio River downstream of the Beaver Valley Power Station (BVPS), effluent

0 4 | during the second quarter of 1981, was found to be 3870 pCi/l. Environmental

0 5 | Technical Specification (ETS), Table 3.2-4, requires that levels above 1390 pCi/l

0 6 | be reported. This is the tenth reported event of this type.

0 7 |

0 8 |

7 6 2

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE			
0	9	Z	Z	X	Z	Z	Z	Z	Z	Z	Z	Z	Z				
7	8	9	10	11	12	12	13	13	14	15	16	19	20				
(17) ERRO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
8		1		0		6		9		0		4		T		0	
21		22		23		24		25		26		27		28		29	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Y	N	Z	Z	Z	Z	Z	Z
32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | During the second quarter of 1981, tritium was discharged from BVPS as a result of

1 1 | normal Reactor Plant Operation at an amount which requires reporting as set forth

1 2 | in the ETS. The discharge was less than 0.13% of the allowable limit noted in

1 3 | 10 CFR 20, Appendix B. An amendment to the ETS has been submitted which would

1 4 | increase the present limit to that in 10 CFR 20.

FACILITY STATUS		POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	E	28	0	9	0	29	N/A	B	31	Contractor Notification	32

ACTIVITY CONTENT
RELEASED OF RELEASE

1	5	2	30	2	14
---	---	---	----	---	----

AMOUNT OF ACTIVITY (35)
N/A

LOCATION OF RELEASE (36)
N/A

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7	0	0	0	37	2	35	N/A		

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
000	(40) N/A

		CCS OF OR DAMAGE TO FACILITY		
TYPE		DESCRIPTION		(43)
1	0	Z	(42) N/A	8108210764-810812

8108210284 810813
PDR ADOCK 05000334
S PDR

ISSUED DESCRIPTION (45) N/A

2 1 X 44

NR USE ONLY

NAME OF PREPARER W. S. Lacey

PHONE: 412-643-8525

Attachment to LER 81-69/04T
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.