

OPERATING DATA REPORT

Received without cover letter.
CORRECTED COPY

DOCKET NO.: 50-311
DATE: July 10, 1981
COMPLETED BY: L.K. Miller
TELEPHONE: 609-365-7000 X507

OPERATING STATUS

1. Unit Name: Salem #2
2. Reporting Period: June 1981
3. Licensed Thermal Power (Mwt): 3411
4. Nameplate Rating (Gross Mwe): 1162
5. Design Electrical Rating (Net Mwe): 1115
6. Maximum Dependable Capacity (Gross Mwe): 1149
7. Maximum Dependable Capacity (Net Mwe): 1104
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reason:
N/A

Notes:



9. Power Level To Which Restricted, If Any (Net Mwe): NONE
10. Reasons For Restrictions, If Any: N/A

	This Month	Year to Date	Cumulative
11. Hours In Reporting Period	720	4,343	10,512
12. Number Of Hours Reactor Was Critical	256.5	457.9	726.1
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	78.6	78.6	78.6
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	78,098	78,098	78,098
17. Gross Electrical Energy Generated (MWH)	12,090	12,090	12,090
18. Net Electrical Energy Generated (MWH)	0	0	0
19. Unit Service Factor	0	0	0
20. Unit Availability Factor	0	0	0
21. Unit Capacity Factor (Using MDC Net)	0	0	0
22. Unit Capacity Factor (Using DER Net)	0	0	0
23. Unit Forced Outage Rate	0	0	0
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End of Report Period, Estimated Date of Startup: _____
26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast	Achieved
6/30/80	8/02/80
9/01/80	6/03/81
9/24/81	NA

8-1-7.R2
Pg.

8108210053 810710
PDR ADOCK 05000311
R PDR

IE24
s
0/1
IE-24