

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

0	1	I				L	D	R	S	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5													
7	8	LICENSEE CODE										14	LICENSE NUMBER										25	LICENSE TYPE										30	CAT										58

CONT

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	2	3	7	7	0	8	1	4	8	1	8	0	8	2	4	8	1	9
50	61									58	69						74	75						80
DOCKET NUMBER											EVENT DATE							REPORT DATE						

0 2 | During an orderly unit shutdown while performing the quarterly timing surveillance of  
0 3 | the main steam isolation valves, valves 2-203-1A and 2-203-1D had closure time limits  
0 4 | of 2.1 and 1.7 seconds respectively. Tech. Spec. Table 3.7.1 requires closure time  
0 5 | limits of between 3 and 5 seconds. Minimal effect upon public health and safety be-  
0 6 | cause remaining MSIV closure times were within Tech. Spec. limits and all valves were  
0 7 | operable. There have been similar occurrences, the last being reported by #81-11/03L-0.  
0 8 |  
7 8 9 80

SYSTEM CODE C D 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE V A L V E X 14				COMP. SUBCODE F 15		VALVE SUBCODE D 16					
EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 4 9 24 26		OCCURRENCE CODE 0 1 28 29		REPORT TYPE T 30		REVISION NO. 0 32									
ACTION TAKEN E 18 33		FUTURE ACTION Z 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED Y 23 41		NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER N 25 43		COMPONENT MANUFACTURER C 6 6 5 26 44 47	

1 0 The timing mechanisms on MSIVs 2-203-1A and 2-203-1D became misadjusted during normal

1 1 plant operation. MSIVs 2-203-1A and 2-203-1D were adjusted and timed at 3.4 and 3.7

1 2 seconds, respectively. The quarterly timing surveillance will continue to be performed

1 3 to ensure proper closure times are maintained.

1 4

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	D	28	0	4	6	29	N/A	B	31	Operator observation	32
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE						
1	6	Z	33	Z	34	N/A	35	N/A	36			
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	Z	38	N/A				
PERSONNEL INJURIES		NUMBER		DESCRIPTION								
1	8	0	0	0	40			N/A				
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION								
1	9	Z	42			N/A						
PUBLICITY		ISSUED		DESCRIPTION								
2	0	N	44			N/A						

NRC USE ONLY

8109030120 810824  
PDR ADCK 05000237  
S PDR

Randy D. Speroff

PHONE 815-942-2920

ATTACHMENT TO LICENSEE EVENT REPORT 81-49/01T-0

COMMONWEALTH EDISON COMPANY (CWE)

DRESDEN UNIT ILDRS-2

DOCKET #050-237

During a normal shutdown of Dresden Station Unit 2 Reactor, the quarterly timing surveillance of the main steam isolation valves was performed. The surveillance testing revealed that MSIVs 2-203-1A and 2-203-1D had closure times of 2.1 and 1.7 seconds, respectively. Technical Specification Table 3.7.1 requires closure time limits of between 3 and 5 seconds. Minimal effect upon public health and safety because remaining MSIV closure times were within Tech. Spec. limits and all valves were operable. There have been similar occurrences at Dresden with last being R. O. #81-11/03L-0.

The timing mechanisms on MSIVs 2-203-1A and 2-203-1D became misadjusted during normal plant operation. The MSIVs were adjusted and retimed resulting in times of 3.4 seconds for 2-203-1A and 3.7 seconds for 2-203-1D. The quarterly timing surveillance of the main steam isolation valves will continue to be performed to ensure proper closure times are maintained.